



Date	Day	Actual	Predicted	Savings	\$Savings	%Savings	Comments	HDD	CDD	
					\$8.50			<b>62.68</b>	<b>0.52</b>	<b>0.84</b>
Jan 2	Sat	66	83	17	\$144	20.45%	average	39	0	
Jan 3	Sun	66	83	17	\$144	20.45%	average	39	0	
Jan 4	Mon	74	87	13	\$107	14.55%		46	0	
Jan 5	Tue	73	83	10	\$85	12.01%		39	0	
Jan 6	Wed	73	80	7	\$63	9.16%		34	0	
Jan 7	Thu	82	87	5	\$44	5.88%		47	0	
Jan 8	Fri	79	88	9	\$78	10.39%	average	49	0	
Jan 9	Sat	79	84	5	\$43	5.96%	average	41	0	
Jan 10	Sun	79	83	4	\$38	5.37%	average	40	0	
Jan 11	Mon	78	85	7	\$55	7.72%		42	0	
Jan 12	Tue	72	86	14	\$120	16.36%		45	0	
Jan 13	Wed	71	85	14	\$119	16.51%		43	0	
Jan 14	Thu	72	80	8	\$67	9.82%		33	0	
Jan 15	Fri	74	83	9	\$76	10.80%	average	39	0	
Jan 16	Sat	74	84	10	\$85	11.91%	average	41	0	
Jan 17	Sun	74	83	9	\$76	10.80%	average	39	0	
Jan 18	Mon	63	80	17	\$143	21.09%		33	0	
Jan 19	Tue	63	76	13	\$108	16.76%		25	0	
Jan 20	Wed	60	77	17	\$142	21.80%		27	0	
Jan 21	Thu	61	77	16	\$134	20.49%		27	0	
Jan 22	Fri	65	77	12	\$100	15.28%	average	27	0	
Jan 23	Sat	65	79	14	\$117	17.51%	average	31	0	
Jan 24	Sun	65	79	14	\$122	18.06%	average	32	0	
Jan 25	Mon	67	79	12	\$100	14.98%		31	0	
Jan 26	Tue	72	79	7	\$62	9.23%		32	0	
Jan 27	Wed	59	80	21	\$177	26.10%		33	0	
Jan 28	Thu	70	79	9	\$79	11.75%		32	0	
Jan 29	Fri	66	81	15	\$126	18.40%	average	35	0	
Jan 30	Sat	66	81	15	\$126	18.40%	average	35	0	
Jan 31	Sun	66	78	12	\$100	15.13%	average	29	0	
Feb 1	Mon	65	78	13	\$108	16.41%		29	0	
<b>Total</b>		<b>2,159</b>	<b>2,522</b>	<b>363</b>	<b>\$3,089</b>	<b>14.41%</b>				
		MCF	MCF	MCF	\$8.50/MCF					

\*\*Day of start-up of new burner resulted in a fuel consumption reduction of 11 Decatherms per day. 14.86% reduction in consumption

\*\* Previous months fuel data shows boiler consumption on a running average over 79 decatherms per day.

\*\* Since Jan 18 running average daily fuel consumption is 65 decatherms per day

\*\* At \$8.50 per decatherm = \$93.50 in fuel savings per day.